## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

## FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





**LISTING No.** 6912-1446:0100 Page 1 of 1

CATEGORY: 6912 -- VOICE COMMUNICATION ACCESSORIES

LISTEE: EVAX SYSTEMS20 McDermott Dr. Branford, CT 06405

Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999

Email: billw@pottersignal.com

**DESIGN:** Models EVAX 25, -25E, -50, -50E, -100, -100E, \*-100M, -150, -150E, -200, -200E, \*-200M, \*

-300, \*-300E, \*-400, \*400E, \*-500, \*500E, \*-600, \*-600E, \*EVX-SC, \*EVX-RM module, \*EVX-RM16 module, audio adjunct system. These units are intended to be used in conjunction with a listed electrically compatible fire alarm control unit to provide voice communication, paging, evacuation tone signals, and voice alarm signals with voice override. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** Input: 24-32 VAC/DC, Standby: 24 VDC, EVAX 25 / 25E / 50/ 50E 7-18 Ah Battery

EVAX -100, -100E, \*-100M, -150, -150E, -200, -200E, \*-200M, \*-300, \*-300E, \*-400, \*400E, \*

-500, \*500E, \*-600, \*-600E 7-24 Ah Battery

**INSTALLATION:** In accordance with listee's printed installation instructions, wiring diagram, applicable codes

and ordinances and in a manner which is acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a voice/tone communication/evacuation/relocation/audio adjunct system for use

with separately listed electrically compatible fire alarm speakers and control units. Supervision is dependent upon the fire alarm control panel. Refer to the control panel's listing and installation instructions for proper configurations. Suitable for high rise applications when used in conjunction with separately listed fire alarm control units. Refer to listee's Installation

Instruction Manual for details.

Revision 12/30/2019 JB



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2020 Listing Expires June 30, 2021

Authorized By: **DAVID CASTILLO**, M.E., F.P.E.

Fire Engineering Division