

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0553:0111 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: SPACE AGE ELECTRONICS 58 Chockett Road, Sterling, MA 01564
Contact: Robert Scholl (508) 485-0966 Fax (508) 485-4740
Email: bobs@1sae.com

DESIGN: Models MBC and BCA battery cabinet enclosures. Minimum thickness .064" cold rolled steel, for batteries with a combined peak voltage of 42.4v.
Refer to listee's data sheets, installation instructions, and manufacturer's drawings for detailed product description, installation, and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and standards, and in a manner acceptable to the Authority Having Jurisdiction.

MARKING: Listee's name, model number, use of product, and UL label.

APPROVAL: Listed as a fire alarm equipment battery cabinet enclosure for use with listee's fire alarm equipment. Refer to listee's installation instruction manual for details.

02-09-16 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division